



NOTES:

1. REFER TO STANDARD DETAIL W6.08 WHEN METER AREA IS NOT ADJACENT TO AN EXTERIOR WALL.
2. METER TO BE SET HORIZONTALLY. RUN WIRE FROM METER TO OUTSIDE FRONT FOR REMOTE READER.
3. METER NOT TO BE SET WITHIN 10' OF ELECTRICAL DISTRIBUTION EQUIPMENT.
4. TURBULENCE COMPENSATOR MIN. 5 PIPE DIA. INLET AND OUTLET.
5. METER BOTTOM TO BE SET BY PLUMBER. COUNTY WILL SET METER HEAD AND OUTSIDE REMOTE. COUNTY ISSUES METER.

CHARLES COUNTY GOVERNMENT

DEPARTMENT OF PLANNING & GROWTH MANAGEMENT

APPROVED:

DIRECTOR OF DEVELOPMENT SERVICES

DATE

WATER / SEWER ENGINEER

DATE

STANDARD DETAIL

INDOOR
F.M. METER
INSTALLATIONS

REVISIONS:

W
6.07